

Safety Notice - Hydrostatic Testing

1. Orange County Cylinder Requalification (OCCR) is an authorized DOT Cylinder Requalifier.
2. Each cylinder bearing a DOT specification must be inspected, retested and marked in conformance with 49 CFR 180.205.
3. Requalification dates are stamped on the cylinder.
4. In addition, a cylinder must be tested and inspected when there is any evidence of damage or any other condition that might make it unsafe for use or transportation, e.g. been in an accident or damaged.
5. No cylinder may be filled and transported unless it is within the requalification period and is properly marked.
6. Hydrostatic testing is a pressure test which tests the measure of expansion under pressure at the time of testing. There is also a visual inspection.
7. Cylinders that pass both the visual inspection and the hydrostatic test may be stamped with the requalification mark and can be filled and transported. The pass/fail criteria differ based on the type of cylinder.
8. If a tank is rejected as it meets a condition for rejection (fails either visual inspection or requalification) owner will be notified in writing and tank must not be filled and transported.
9. Any tank(s) or customer-owned equipment that is not picked up after our reasonable attempts to contact you for more than (90) days will be considered forfeited and become property of OCCR.